

Drinking Water Laboratory Test Report

CLIENT INFORMATION

REPORT ISSUE DATE:

6/23/2025

REPORT #:

25-07386

CLIENT/CLIENT ADDRESS

Paladin Career & Technical High School
10220 Goldenrod St NW
Coon Rapids, MN 55448

SCHOOL/ADDRESS

Paladin Career & Technical High School
10220 Goldenrod St NW
Coon Rapids, MN 55448

SAMPLE INFORMATION

RECEIPT DATE/TIME:

6/13/2025 at 15:00

TEMP OF SAMPLE UPON RECEIPT:

18 °C

COLLECTED BY:

TCWC

CLIENT

Other

LABORATORY		SAMPLE COLLECTION			SAMPLE ANALYSIS				SAMPLE RESULTS
SAMPLE ID	ANALYTE	LOCATION	DATE	TIME	DATE	TIME	METHOD	ACTION LEVEL*	RESULT
25-07386	Lead	Staff Lounge - Refrigerator Water	6/11/2025	11:30	6/18/2025	11:25	SM3113B-93	5 µg/L	<2.00 µg/L
25-07387	Lead	Staff Lounge - Sink	6/11/2025	11:30	6/18/2025	11:31	SM3113B-93	5 µg/L	<2.00 µg/L
25-07388	Lead	Sky Room - Sink	6/11/2025	11:31	6/18/2025	11:37	SM3113B-93	5 µg/L	<2.00 µg/L
25-07389	Lead	LLab 3 Hall - Bottle Filler	6/11/2025	11:34	6/18/2025	11:43	SM3113B-93	5 µg/L	<2.00 µg/L
25-07390	Lead	LLab 3 Hall - Left Drinking Fountain	6/11/2025	11:35	6/19/2025	12:00	SM3113B-93	5 µg/L	<2.00 µg/L
25-07391	Lead	LLab 3 Hall - Right Drinking Fountain	6/11/2025	11:36	6/19/2025	12:06	SM3113B-93	5 µg/L	<2.00 µg/L
25-07392	Lead	Oasis Room - Left Sink	6/11/2025	11:40	6/19/2025	12:12	SM3113B-93	5 µg/L	<2.00 µg/L
25-07393	Lead	Oasis Room - Right Sink	6/11/2025	11:41	6/19/2025	12:18	SM3113B-93	5 µg/L	<2.00 µg/L
25-07394	Lead	Front Entry - Bottle Filler	6/11/2025	11:44	6/19/2025	12:24	SM3113B-93	5 µg/L	<2.00 µg/L
25-07395	Lead	Front Entry - Left Drinking Fountain	6/11/2025	11:45	6/19/2025	12:31	SM3113B-93	5 µg/L	<2.00 µg/L
25-07396	Lead	Front Entry - Right Drinking Fountain	6/11/2025	11:46	6/23/2025	11:34	SM3113B-93	5 µg/L	<2.00 µg/L
25-07397	Lead	Kitchen - Food Prep Sink	6/11/2025	11:50	6/23/2025	11:40	SM3113B-93	5 µg/L	2.75 µg/L

*The action level is determined by MN Statute 121A.335.

NOTES

Samples preserved on 6/14/2025 at 9:30.

APPROVED BY:



Frances Turner - Laboratory Director

Minnesota Laboratory ID # 027-053-119

The result(s) listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. The analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.